

Polar Spring Water AB  
Hasse Gramén  
Stommenvägen 6  
511 98 HYSSNA

**AR-18-SB-085630-01**

**EUSEJO2-00309092**

Client code:: LW8652502

 Reference:  
Grönared

## ANALYTICAL REPORT

Sample code:	<b>527-2018-12040468</b>	arrival Temperature:	13,3
Client Sample:	Grönared	Sample date:	2018-12-04
Received:	2018-12-04	Sampling temp	8,5
Report finished:	2018-12-11	Sampling time	12:00
Start of analysis	2018-12-04 21:40		
Sample type:	Dricksvatten (D)		
Matrix	Dricksvatten hos användare		

Test code	Analysis	Result Unit	Uncert.	Method/ref.	Lab
UM25G [a]	Aerobic Plate Count 22°C	< 1 cfu/ml		ISO 6222	EUSEJO2
UM25U [a]	Coliforms 35°C	< 1 cfu/100 ml		SS 028167-2 mod.	EUSEJO2
UM25U [a]	Escherichia coli	< 1 cfu/100 ml		SS 028167-2 mod.	EUSEJO2
UM25M [a]	Slow-growing bacteria	< 1 cfu/ml		ISO 6222 mod.	EUSEJO2

**Sample conclusion:**  
Tjänligt (Bedömning utförd enl. SLV FS 2001:30)

 Pernilla Josefsson, ASM  
Contact: mikro.asm@eurofins.se

This test report has been created electronically and has been verified and authorised.

**Explanations of which laboratory that has performed the tests and to accreditation/recognitions**

Lab	Name	Mark.	Accreditation/Recognition
EUSEJO2	Eurofins Food & Feed Testing Sweden (Jönköping)	[a]	ISO/IEC 17025:2005 SWEDAC 1977

[a] in front of a parameter indicates that the test has been performed under accreditation

**Explanations**

Measurement uncertainty, unless otherwise stated, are reported as expanded uncertainty with coverage factor 2. Exceptions related to analysis performed outside Sweden may occur. Additional information can be obtained upon request.

AR-007 V-SB v6